

1
2
3
4
5
6
7
8

(BSP August 4, 2003)

The second paragraph of Section 6-02.3(25)B is revised to read as follows:

The Contractor shall fabricate all prestressed concrete girders using the Contractor-Provided mix design appropriate for the design strength specified for each girder in accordance with Sections 6-02.3(2)A and 9-19.1 as supplemented in these Special Provisions, and as approved by the Engineer. The temperature of the concrete when placed shall be between 10C and 32C.